ZONA	ORIENTACION	% V/S TRANSMITANCIA TERMICA U											
TERMICA	U [W/m²K]	≤0,6	≤0,8	≤1,2	≤1,6	≤2,0	≤2,4	≤2,8	≤3,2	≤3,6	≤4,0	≤4,4	≤5,8
A	Norte	100%	100%	100%	100%	100%	98%	97%	95%	94%	91%	88%	50%
	0 - P	100%	100%	99%	96%	94%	91%	87%	84%	80%	75%	69%	30%
	Sur	94%	93%	91%	89%	85%	82%	78%	74%	69%	63%	57%	25%
	POND	54%	53%	52%	51%	50%	49%	48%	46%	44%	42%	40%	25%
В	Norte	100%	99%	98%	97%	96%	94%	92%	90%	88%	85%	82%	30%
	0 - P	92%	91%	89%	87%	84%	81%	78%	75%	71%	66%	60%	20%
	Sur	86%	84%	81%	78%	75%	71%	68%	64%	59%	54%	47%	10%
	POND	52%	51%	49%	47%	46%	45%	43%	42%	40%	38%	35%	10%
С	Norte	96%	95%	94%	93%	91%	90%	88%	85%	83%	79%	75%	40%
	0 - P	82%	81%	79%	77%	75%	72%	69%	66%	62%	58%	52%	35%
	Sur	75%	73%	70%	67%	64%	61%	58%	54%	49%	44%	38%	15%
	POND	47%	46%	45%	44%	42%	41%	39%	37%	35%	33%	30%	15%
D	Norte	94%	93%	91%	89%	87%	85%	83%	80%	77%	73%	69%	25%
	0 - P	73%	72%	70%	68%	65%	63%	60%	57%	53%	49%	44%	15%
	Sur	62%	61%	59%	57%	54%	51%	48%	44%	40%	35%	29%	10%
	POND	43%	42%	41%	40%	38%	37%	35%	33%	31%	28%	25%	10%
Е	Norte	90%	89%	87%	85%	83%	80%	78%	75%	71%	67%	61%	10%
	0 - P	63%	62%	60%	58%	56%	54%	51%	48%	45%	41%	35%	8%
	Sur	51%	50%	48%	46%	44%	41%	38%	35%	31%	26%	20%	5%
	POND	39%	38%	37%	36%	34%	32%	30%	28%	26%	23%	19%	5%
F	Norte	88%	86%	83%	80%	78%	76%	73%	69%	65%	60%	54%	0%
	0 - P	54%	53%	51%	49%	47%	45%	42%	40%	36%	32%	27%	0%
	Sur	41%	40%	38%	36%	34%	31%	28%	25%	21%	17%	12%	0%
	POND	36%	35%	33%	31%	30%	28%	26%	24%	21%	17%	13%	0%
G	Norte	84%	82%	79%	76%	74%	71%	67%	64%	59%	54%	46%	0%
	0 - P	43%	42%	41%	40%	38%	36%	34%	31%	28%	24%	20%	0%
	Sur	31%	30%	28%	26%	24%	21%	19%	16%	13%	8%	0%	0%
	POND	32%	31%	29%	27%	26%	24%	21%	19%	16%	12%	0%	0%
н	Norte	77%	76%	74%	72%	69%	66%	62%	58%	53%	47%	38%	0%
	0 - P	34%	33%	32%	31%	29%	27%	25%	23%	20%	16%	12%	0%
	Sur	30%	29%	27%	25%	23%	20%	18%	15%	12%	7%	0%	0%
	POND	31%	30%	28%	26%	25%	23%	20%	18%	15%	11%	0%	0%
I	Norte	75%	73%	70%	67%	64%	61%	57%	52%	46%	39%	30%	0%
	0 - P	43%	42%	41%	40%	38%	36%	34%	31%	28%	24%	20%	0%
	Sur	28%	27%	25%	23%	21%	18%	16%	13%	10%	5%	0%	0%
	POND	29%	28%	26%	24%	23%	21%	18%	16%	13%	10%	0%	0%

TABLA 4. Porcentaje máximo permitido de superficie de ventanas según orientación y valor U, para cada zona térmica.